## **RESOLUTION 2011-433**

## RESOLUTION OF THE TOWNSHIP OF BARNEGAT, COUNTY OF OCEAN, STATE OF NEW JERSEY, DENYING THE RELEASE OF A MAINTENANCE BOND FOR WATER SYSTEM IMPROVEMENTS FOR FOUR SEASONS AT MIRAGE, SECTION 7

**WHEREAS**, K. Hovnanian, the developer of Four Seasons at Mirage, Section 7 has requested a release of the Maintenance Bond for Water System Improvements; and

**WHEREAS**, the Township Engineer has inspected subject site, and recommends denying the release of the Maintenance Bond for Water System Improvements until the following punch list is completed:

- 1. Clean out valve box at 25 Rocky Brook Drive
- 2. Clean out valve box at intersection of Whitewater Drive and Rocky Brook Drive
- 3. Clean out valve box at intersection of Shady Stream Road and Hidden Lake Circle
- 4. Clean out valve box at intersection of Silver Lake Drive and Meadowbrook Alley
- 5. Clean out valve box at intersection of Silver Lake Drive and Little Falls Court
- 6. Clean out valve box at intersection of Rocky Brook Drive and Five Bridges Court
- 7. Clean out valve box at intersection of Shady Stream Road and Spout Terrace
- 8. Clean out hydrant valve box at 9 Rocky Brook Drive
- 9. Clean out hydrant valve box at 15 Shady Stream Road
- 10. Clean out hydrant valve box in Old Mill Court
- 11. Clean out hydrant valve box in Spout Terrace
- 12. Replace broken valve box casting and clean out valve box at 1 Silver Lake Drive
- 13. Replace broken valve box casting and clean out valve box at 11 Silver Lake Drive
- 14. Replace broken valve box casting and clean out valve box at 29 Shady Stream Road
- 15. Replace broken valve box casting and clean out valve box at intersection of Silver Lake Drive and Shady Stream Road
- 16. Replace broken hydrant valve box casting and clean hydrant valve box at 7 Silver Lake Drive
- 17. Replace broken hydrant valve box casting and clean out hydrant valve box in Little Falls
- 18. Replace broken valve box casting and clean out valve box at intersection of Hidden Lake Circle and Rocky Brook Drive

**THEREFORE BE IT RESOLVED** by the Township Committee of the Township of Barnegat, County of Ocean, State of New Jersey that the request for release of the Maintenance for Four Seasons at Mirage, Section 7 Water System Improvements is hereby denied based on the recommendation of the Township Engineer, in his letter dated August 15, 2011.

## **CERTIFICATION**

I, Sharon L. Auer, Acting Municipal Clerk of the Township of Barnegat, County of Ocean, State of
New Jersey do hereby certify that the foregoing resolution was duly adopted by the Barnegat
Township Committee at their regular meeting held on the 6 <sup>th</sup> day of September, 2011, at the
Municipal Complex, 900 West Bay Avenue, Barnegat, New Jersey.

Sharon L. Auer Acting Municipal Clerk