

RESOLUTION 2011-436

**RESOLUTION OF THE TOWNSHIP OF BARNEGAT,
COUNTY OF OCEAN, STATE OF NEW JERSEY,
DENYING THE RELEASE OF A MAINTENANCE BOND
FOR WATER SYSTEM IMPROVEMENTS FOR
FOUR SEASONS AT MIRAGE, SECTION 9**

WHEREAS, K. Hovnanian, the developer of Four Seasons at Mirage, Section 9 has requested a release of the Maintenance Bond for Water System Improvements; and

WHEREAS, the Township Engineer has inspected subject site, and recommends denying the release of the Maintenance Bond for Water System Improvements until the Punch List listed below is completed;

- 1, Clean out valve box at intersection of Mirage Blvd and Lily Pond Lane
2. Clean out valve box across from 169 Mirage Blvd.
3. Clean out valve box at intersection of Mirage Blvd. and Lakeland Drive
4. Clean out valve box adjacent to 138 Lakeland Drive and on Mirage Blvd
5. Clean out hydrant valve box across from Running Brook Terrace on Mirage Blvd
6. Clean out valve box at intersection of Mirage Blvd and Running Brook Terrace
7. Clean out valve box at 202 Mirage Blvd
8. Valve box is sealed shut and must be opened at intersection of Mirage Blvd and Bridgewaters Passage
9. Replace broken valve box and clean out the valve box on Miles Pond Place
10. Clean out two (2) valve boxes at intersection of Mirage Blvd and Edgewater Path
11. Clean out valve box at intersection of Edgewater Path and Jonahs Pond Lane
12. Clean out valve box between 7 & 11 Edgewater Path
13. Replace broken hydrant valve box and clean out on Geyser Place
14. Clean out hydrant valve box between 23 & 25 Jonahs Pond Lane
15. Clean out valve box at 25 Jonahs Pond Lane
16. Clean out valve box at intersection of Jonahs Pond Lane and Headwaters Place
17. Clean out hydrant valve box on Headwaters Place
18. Clean out valve box between 11 & 15 Jonahs Pond Lane
19. Clean out valve box at intersection of Jonahs Pond Lane and Whitecaps Terrace
20. Clean out valve box at intersection of Jonahs Pond Lane and Overbrook Court
21. Valve box is sealed shut and must be opened at 200 Mirage Blvd

THEREFORE BE IT RESOLVED by the Township Committee of the Township of Barnegat, County of Ocean, State of New Jersey that the request for release of the Maintenance for Four Seasons at Mirage, Section 9 Water System Improvements is hereby denied based on the recommendation of the Township Engineer, in his letter dated August 15, 2011.

CERTIFICATION

I, Sharon L. Auer, Acting Municipal Clerk of the Township of Barnegat, County of Ocean, State of New Jersey do hereby certify that the foregoing resolution was duly adopted by the Barnegat Township Committee at their regular meeting held on the 6th day of September, 2011, at the Municipal Complex, 900 West Bay Avenue, Barnegat, New Jersey.

Sharon L. Auer
Acting Municipal Clerk