

RESOLUTION 2016-337

RESOLUTION OF THE TOWNSHIP OF BARNEGAT, COUNTY OF OCEAN, STATE OF NEW JERSEY, DENYING REQUEST OF RELEASE OF PERFORMANCE GUARANTEE FOR OFF SITE SANITARY SEWER SYSTEM IMPROVEMENTS FOR LIGHTHOUSE CROSSING

WHEREAS, D&F Barnegat Developments LLC, the developer of Lighthouse Crossing, has requested a release of the Performance Guarantee for the Off-site Sanitary Sewer System Improvements; and

WHEREAS, the Township Engineer has inspected subject site, and recommends denying the release of the Performance Guarantee for Off-Site Sanitary Sewer System Improvements;

THEREFORE BE IT RESOLVED by the Township Committee of the Township of Barnegat, County of Ocean, State of New Jersey that the request for the release of the Performance Guarantee for the Off-site Sanitary Sewer System Improvements for Lighthouse Crossing. is hereby denied based on the recommendation of the Township Engineer, in his letter dated August 12, 2016 contingent upon the following;

1. All 8" PVC pipe must be cleaned and video taped prior to release
2. All manholes must be cleaned prior to release.
3. Install cap and brass plug on the cleanout in the 6" PVC lateral at SMH #4.
Clean all debris from cleanout stack and 6" PVC lateral.
4. Provide gravity sewer and force main testing report.
5. Provide as-built plans in GPS format.

CERTIFICATION

I, Michele A. Rivers, Municipal Clerk of the Township of Barnegat, County of Ocean, State of New Jersey do hereby certify that the foregoing resolution was duly adopted by the Barnegat Township Committee at their regular meeting held at the Municipal Complex, 900 West Bay Avenue, Barnegat, New Jersey, on the 6th day of September 2016.

Michele A. Rivers, RMC
Municipal Clerk